



Figure 1

(5) Grade requirements where curbs and sidewalks are present.

(i) The driveway approaches shall be installed 1 1/2 inches above the adjacent roadway or the gutter grade to maintain proper drainage. See Figure 5.

(ii) The difference between the cross slope of the roadway and the upward grade of the driveway approach shall not exceed 8.0%.

(iii) When a planted area exists in front of the sidewalk, one of the following three cases shall apply:

(A) When the grass strip between the curb and the sidewalk is wide enough to maintain an 8.0% maximum driveway approach grade, construct the driveway as shown in Figure 2.